



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Lucas County
Toledo Christian School
Construction
Storm Water

August 9, 2012

Dr. Michael Chivalette
Superintendent
Toledo Christian School
2303 Brookford Drive
Toledo, Ohio 43614

Mr. Norm White
Spieker Company
8350 Fremont Pike
Perrysburg, Ohio 43552

Dear Dr. Chivalette and Mr. White:

On July 24, 2012, I inspected Toledo Christian School at 2303 Brookford Drive, Toledo (photos taken). The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No 2GC02823. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at Toledo Christian School are complete. The buildings and parking lot have been constructed. The site has been seeded and grass has germinated. It was not evident how the post construction storm water management requirements of the permit will be met.

A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or

Dr. Michael Chivalette
Mr. Norm White
August 9, 2012
Page Two

- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

It appears that the site has not yet reached a 70% density of perennial vegetative cover over the entire site. When this has been achieved and you have installed the post construction storm water management facilities required by the permit, please file the NOT form. The NOT form and instructions can be found on our website:

<http://www.epa.ohio.gov/dsw/storm/stormform.aspx>

NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

Within 10 days of the date on this letter, please submit a written description of how the post construction storm water management requirements will be met for this project. Your reply should include the type(s) of practices you are implementing and the basis for their design.

If there are any questions, please contact me at 419-373-3011.

Sincerely,



Bernard E. Weik
Division of Surface Water
Storm Water Program

/jlm

ec: Patekka Pope Bannister, City of Toledo Division of Environmental Services
Tracking