



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Paulding County
Oakwood Municipal Gas
Construction
Storm Water

August 9, 2012

Mr. Bud Henke
Oakwood Municipal Gas
228 North 1st Street
Oakwood, Ohio 45873

Dear Mr. Henke:

On July 9, 2012, I inspected Oakwood Municipal Gas on 228 North 1st Street, Oakwood. The purpose of my visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02898. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Our records indicate that there are no co-permittees on this project.

It appears that construction activities at Oakwood Municipal Gas are complete. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

The NOT form and instructions can be found on our website:

<http://www.epa.ohio.gov/dsw/storm/stormform.aspx>

NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3011.

Sincerely,

Bernard E. Weik
Division of Surface Water
Storm Water Program

/jlm

ec: Ken Kottenbrock, District Conservationist
Tracking