



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Hancock County
ALDI-Findlay, Ohio
Construction
Stormwater

August 9, 2012

Mr. Russ White
Division Vice President
ALDI Inc. – Springfield Division
4400 South Charleston Pike
P.O. Box 2997
Springfield, Ohio 45502

Dear Mr. White:

On June 7, 2012, Jessica Heitman and I inspected ALDI-Findlay Ohio on 2227 Tiffin Avenue, Findlay. The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC03131. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Our records indicate that there are no co-permittees on the project.

At the time of the inspection, no earthwork was occurring and no construction equipment was present. When construction does commence, please remember the permit requirements for storm water management during construction and post construction, such as weekly self-inspections and the requirement to apply cover within seven days on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven days of grubbing and before any grading.

Please send a written reply within 10 days of the date of this letter describing how the post construction storm water management requirements will be met for this project. Your reply should include the type(s) of practices you are implementing and the basis for their design.

If there are any questions, please contact me at 419-373-3011.

Sincerely,

Bernard E. Weik
Division of Surface Water
Storm Water Program

/jlm

cc: Ms. Meghan Clement, City of Findlay
Tracking