Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Sandusky County
York Elementary School
Construction
Storm Water

August 9, 2012

Ms. Kim Schubert
Bellevue City Schools
125 North Street
P.O. Box 8003
Bellevue, Ohio 44811

Dear Ms. Schubert:

On July 10, 2012, I inspected York Elementary School at 2314 East McPherson Highway, Clyde. The purpose of my visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC03169. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Our records indicate that there are no co-permittees on this project.

At the time of the inspection, no earthwork was occurring and no construction equipment was present. When construction does commence, please remember the permit requirements for storm water management during construction and post construction, such as weekly self- inspections and the requirement to apply cover within seven days on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven days of grubbing and before any grading.

Please send a written reply within 10 days of the date of this letter describing how the post construction storm water management requirements will be met for this project. Your reply should include the type(s) of practices you are implementing and the basis for their design.

If you have any questions, please contact me at 419-373-3011.

Sincerely,

Bernard E. Weik

Bernard E. Weik
Division of Surface Water
Storm Water Program

/jlm
ec: Becky Duncan, District Conservationist
Tracking

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov