

Ohio EPA DSW Storm Water Section, Construction Site Visit Information Form

Inspector initials: EJC

Visit date: 8/21/21 Permit # 16C039.39*AG

Site Name: Princeton MS/HS Campus

Site Address: 1157 Chester Road, Cincinnati OH

People contacted on site (attach business cards): _____

Their phone and e-mail: _____

1. Did you see the following on site?

ITEM	Yes/No	Not requested	Comments
NOI	No		DAG just took over as GC
Coverage letter	No		
SWP3	Yes		
Inspection records	Yes		DAG took over in July
Contractor & Subs signature document	No		

2. Acreage disturbed (circle): < 1 acre >1 but <5 acres >5 but <10 acres ^{86.28} >10 acres ??

3. Site status: Clearing/grubbing Rough grading Storm sewers in Streets in
Utilities installed Final grade Final stabilization

4. Are BMPs needed on site? Yes

5. Are BMPs on site effective? All* Some None No BMPS

Explain: * all but one little section (apt. 50ft)

6. What post construction controls are shown on the SWP3? 2 Detention Ponds
1 parking lot CB goes straight off site on asphalt

7. Were photos taken and saved? Yes

8. Was an NOV issued? No

Notes:

- Very good for a larger site.
- Only one small section of silt fence down