



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 16, 2012

Educational Service Center of Central Ohio  
Alan Hutchinson  
2080 Citygate Drive  
Columbus, Ohio 43219

Re: **Pre-Construction Storm Water Inspection at Educational Service Center of Central Ohio  
Franklin County  
Permit Number: 4GC03795\*AG**

Dear Mr. Hutchinson:

This letter is written regarding the storm water inspection conducted by Abigail Tamkin, Brittany Turner, and Kathryn Rumora of the Ohio EPA at the Educational Service Center of Central Ohio on July 5, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

- It appears construction has recently commenced with grading activities noted. In accordance with the General Permit, sediment controls must be established within seven days and maintained throughout all Earth disturbing activities.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

FOR  
Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Educational Service Center 7-5-2012

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)