



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Wood County  
Five Point Road MHP WWTP  
Ohio EPA Permit No. 2PY00073\*AD  
NPDES Permit No. OH0141615

August 23, 2012

Ms. Michelle Myers, Owner  
Five Point MHP  
24730 State Route 199  
Perrysburg, Ohio 43551

Dear Ms. Myers:

A review of the self-monitoring reports that are submitted under the National Permit Discharge Elimination System Permit (NPDES) for the Five Point Road Mobile Home Park (MHP) Wastewater Treatment Plant (WWTP) shows that this facility is in significant non-compliance (SNC) for the following parameters at outfall number 001: Ammonia. I am enclosing a list of violations for this facility for the period of January 1, 2012, through June 30, 2012.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters.

Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

Before we initiate enforcement action, we would like to work with you to achieve satisfactory progress to bring this facility back into compliance. Within 21 days of the date of this letter, please submit, in writing, the actions that you propose to undertake in order to return your facility into compliance with your NPDES permit. You will also need to give us a timetable for these actions that does not extend past February 28, 2013. These actions and timetable may also be submitted by email to me at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us).

If you wish to meet with us to discuss this matter, please contact me at 419-373-3016 within 10 days of receiving this letter in order to set up a meeting.

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/jlm

Enclosure

pc: Clean Water Service Inc.  
ec: Thomas Poffenbarger, DSW-NWDO  
Tracking

## Compliance Data for Five Point MHP between 1/1/2012 to 7/1/2012

### Summary

Permit Effluent Limit Violations: 23

Permit Effluent Code Violations: 0

Permit Effluent Frequency Violations: 0

Compliance Schedule Violations: 0

| Limit Violations |         |                         |            |       |                |                |
|------------------|---------|-------------------------|------------|-------|----------------|----------------|
| Reporting Period | Station | Parameter               | Limit Type | Limit | Reported Value | Violation Date |
| January 2012     | 001     | Dissolved Oxygen        | 1D Conc    | 6.0   | 3.81           | 1/4/2012       |
| January 2012     | 001     | Dissolved Oxygen        | 1D Conc    | 6.0   | 3.2            | 1/9/2012       |
| January 2012     | 001     | Dissolved Oxygen        | 1D Conc    | 6.0   | 4.04           | 1/17/2012      |
| January 2012     | 001     | Dissolved Oxygen        | 1D Conc    | 6.0   | 4.2            | 1/24/2012      |
| February 2012    | 001     | CBOD 5 day              | 30D Conc   | 10.0  | 12.            | 2/1/2012       |
| April 2012       | 001     | Total Suspended Solids  | 30D Conc   | 12.0  | 16.            | 4/1/2012       |
| April 2012       | 001     | Nitrogen, Ammonia (NH3) | 30D Conc   | 3.0   | 5.             | 4/1/2012       |
| April 2012       | 001     | CBOD 5 day              | 30D Conc   | 10.0  | 31.            | 4/1/2012       |
| April 2012       | 001     | Nitrogen, Ammonia (NH3) | 1D Conc    | 4.5   | 5.             | 4/3/2012       |
| April 2012       | 001     | CBOD 5 day              | 1D Conc    | 15.0  | 31.            | 4/3/2012       |
| April 2012       | 001     | Dissolved Oxygen        | 1D Conc    | 6.0   | 5.6            | 4/9/2012       |
| May 2012         | 001     | Nitrogen, Ammonia (NH3) | 30D Conc   | 1.5   | 3.             | 5/1/2012       |
| May 2012         | 001     | Fecal Coliform          | 30D Conc   | 1000  | 1100.          | 5/1/2012       |
| May 2012         | 001     | Dissolved Oxygen        | 1D Conc    | 6.0   | 5.7            | 5/1/2012       |
| May 2012         | 001     | Chlorine, Total Residu  | 1D Conc    | 0.019 | .38            | 5/8/2012       |
| May 2012         | 001     | Dissolved Oxygen        | 1D Conc    | 6.0   | 5.2            | 5/8/2012       |
| May 2012         | 001     | Nitrogen, Ammonia (NH3) | 1D Conc    | 2.2   | 3.             | 5/15/2012      |
| May 2012         | 001     | Dissolved Oxygen        | 1D Conc    | 6.0   | 5.6            | 5/15/2012      |
| May 2012         | 001     | Chlorine, Total Residu  | 1D Conc    | 0.019 | 1.46           | 5/23/2012      |
| May 2012         | 001     | Dissolved Oxygen        | 1D Conc    | 6.0   | 5.87           | 5/23/2012      |

|           |     |                         |          |      |      |           |
|-----------|-----|-------------------------|----------|------|------|-----------|
| June 2012 | 001 | Total Suspended Solids  | 30D Conc | 12.0 | 13.  | 6/1/2012  |
| June 2012 | 001 | Nitrogen, Ammonia (NH3) | 30D Conc | 1.5  | 2.   | 6/1/2012  |
| June 2012 | 001 | Dissolved Oxygen        | 1D Conc  | 6.0  | 4.64 | 6/19/2012 |

Flow Data for Five Point MHP between 1/1/2012 and 7/1/2012

|                          | Date      | Flows (GPD) |
|--------------------------|-----------|-------------|
| Ten Highest Flows        | 6/25/2012 | 1560        |
|                          | 6/21/2012 | 1375        |
|                          | 6/28/2012 | 1375        |
|                          | 4/5/2012  | 1350        |
|                          | 4/25/2012 | 1350        |
|                          | 5/16/2012 | 1350        |
|                          | 6/11/2012 | 1350        |
|                          | 6/26/2012 | 1350        |
|                          | 1/9/2012  | 1300        |
|                          | 1/25/2012 | 1300        |
| <b>Average Flow Rate</b> |           | 1123        |