



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 24, 2012

Re: Guernsey County
Seneca Lake Campground
Notice of Violation
OPX00002; OH0059102
Correspondence (PWW)

Mr. Boris Slogar, Chief Engineer
Muskingum Watershed Conservancy District
1319 3rd Street, NW
P.O. Box 349
New Philadelphia, Ohio 44663

Dear Mr. Slogar:

We have received your self-monitoring reports covering the months of April through May 2012 for the Seneca Lake Lagoon wastewater facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00665	Phosphorus, Total (P)	4/1/2012	30D Conc	1.0	2.16
001	00665	Phosphorus, Total (P)	4/2/2012	1D Conc	1.5	2.16

* 1D Conc is equal to the Daily Maximum concentration limit
 1D Qty is equal to the daily maximum loading limit.
 7D Conc is equal to the weekly average concentration limit.
 7D Qty is equal to the weekly average loading limit.
 30D Conc is equal to the monthly average concentration limit.
 30D Qty is equal to the monthly average loading limit

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Gary Taylor, Operator, MWCD