



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Wood County
Evansville WWTP
Ohio EPA Permit No. 2PG00117
NPDES Permit No. OH0141917

August 28, 2012

Mr. Jerry Greiner, Executive Director
Evansville Western Railroad (CSX) WWTP
12560 Middleton Pike
P.O. Box 348
Bowling Green, Ohio 43402

Dear Mr. Greiner:

A review of the self-monitoring reports that are submitted under the National Permit Discharge Elimination System (NPDES) permit for the Evansville Western Railroad Wastewater Treatment Plant (WWTP) shows that this facility is in significant non-compliance (SNC) for the following parameters at outfall number 001: Total Suspended Solids, and Ammonia. I am enclosing a list of violations for this facility for the period of January 1, 2012, through June 30, 2012.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters.

Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

Before we initiate enforcement action, we would like to work with you to achieve satisfactory progress to bring this facility back into compliance. Within 21 days of the date of this letter, please submit, in writing, the actions that you propose to undertake in order to return your facility into compliance with your NPDES permit. You will also need to give us a timetable for these actions that does not extend past February 28, 2013. These actions and timetable may also be submitted by email to me at patricia.tebbe@epa.state.oh.us.

If you wish to meet with us to discuss this matter, please contact me at 419-373-3016 within 10 days of receiving this letter in order to set up a meeting.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/jlm
Enclosure

ec: Thomas Poffenbarger, DSW-NWDO
Tracking

Compliance Data for Evansville Western Railroad (CSX) WWTP between 1/1/2012 to 7/1/2012

Summary

Permit Effluent Limit Violations: 25
 Permit Effluent Code Violations: 0
 Permit Effluent Frequency Violations: 0
 Compliance Schedule Violations: 0

Limit Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2012	001	Total Suspended Solids	30D Conc	12	98.	1/1/2012
January 2012	001	Total Suspended Solids	7D Conc	18	98.	1/1/2012
January 2012	001	Nitrogen, Ammonia (NH3	30D Conc	3.0	30.9	1/1/2012
January 2012	001	Nitrogen, Ammonia (NH3	7D Conc	4.5	30.9	1/1/2012
February 2012	001	Total Suspended Solids	30D Conc	12	24.	2/1/2012
February 2012	001	Total Suspended Solids	7D Conc	18	24.	2/1/2012
February 2012	001	Nitrogen, Ammonia (NH3	30D Conc	3.0	30.3	2/1/2012
February 2012	001	Nitrogen, Ammonia (NH3	7D Conc	4.5	30.3	2/1/2012
March 2012	001	Total Suspended Solids	30D Conc	12	36.	3/1/2012
March 2012	001	Total Suspended Solids	7D Conc	18	36.	3/1/2012
March 2012	001	Nitrogen, Ammonia (NH3	30D Conc	3.0	40.6	3/1/2012
March 2012	001	Nitrogen, Ammonia (NH3	7D Conc	4.5	40.6	3/1/2012
April 2012	001	Total Suspended Solids	30D Conc	12	95.	4/1/2012
April 2012	001	Total Suspended Solids	7D Conc	18	95.	4/1/2012
April 2012	001	Nitrogen, Ammonia (NH3	30D Conc	3.0	16.2	4/1/2012
April 2012	001	Nitrogen, Ammonia (NH3	7D Conc	4.5	16.2	4/1/2012
April 2012	001	CBOD 5 day	30D Conc	10	24.	4/1/2012
April 2012	001	CBOD 5 day	7D Conc	15	24.	4/1/2012
April 2012	001	pH	1D Conc	6.5	6.3	4/3/2012
May 2012	001	Total Suspended Solids	30D Conc	12	19.	5/1/2012

May 2012	001	Total Suspended Solids	7D Conc	18	19.	5/1/2012
June 2012	001	Total Suspended Solids	30D Conc	12	27.	6/1/2012
June 2012	001	Total Suspended Solids	7D Conc	18	27.	6/1/2012
June 2012	001	Nitrogen, Ammonia (NH3)	30D Conc	1.0	5.	6/1/2012
June 2012	001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	5.	6/1/2012