



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Wood County  
Maurers MHP WWTP  
Ohio EPA Permit No. 2PY00005  
NPDES Permit No. OH0078450

August 28, 2012

Mr. Allen E. Steinke, President  
Maurers MHP  
17910 North Dixie Highway  
Bowling Green, Ohio 43402

Dear Mr. Steinke:

A review of the self-monitoring reports that are submitted under the National Permit Discharge Elimination System (NPDES) permit for the Maurer Mobile Home Park (MHP) Wastewater Treatment Plant (WWTP) shows that this facility is in significant non-compliance (SNC) for the following parameters at outfall number 001: CBOD<sub>5</sub>. I am enclosing a list of violations for this facility for the period of January 1, 2012, through June 30, 2012.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters.

Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

Before we initiate enforcement action, we would like to work with you to achieve satisfactory progress to bring this facility back into compliance. Within 21 days of the date of this letter, please submit, in writing, the actions that you propose to undertake in order to return your facility into compliance with your NPDES permit. You will also need to give us a timetable for these actions that does not extend past February 28, 2013. These actions and timetable may also be submitted by email to me at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us).

If you wish to meet with us to discuss this matter, please contact me at 419-373-3016 within 10 days of receiving this letter in order to set up a meeting.

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/jlm

Enclosure

cc: Thomas Poffenbarger, DSW-NWDO  
Tracking

## Compliance Data for Maurers MHP between 1/1/2012 to 7/1/2012

### Summary

Permit Effluent Limit Violations: 5  
 Permit Effluent Code Violations: 0  
 Permit Effluent Frequency Violations: 0  
 Compliance Schedule Violations: 0

Limit Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2012	001	CBOD 5 day	30D Qty	1.1	1.30583	2/1/2012
February 2012	001	CBOD 5 day	1D Qty	1.7	3.07342	2/3/2012
March 2012	001	Nitrogen, Ammonia (NH3)	30D Qty	0.9	1.14439	3/1/2012
March 2012	001	CBOD 5 day	30D Qty	1.1	1.46858	3/1/2012
March 2012	001	CBOD 5 day	1D Qty	1.7	2.51324	3/2/2012