Ohio | Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 28, 2012

Re: Morgan County
ODOT PID 79336
Storm Water Construction Activity
0GC00650*AG

Mr. Blake Brown
ODOT District 10
338 Muskingum Drive
Marietta, Ohio 45750

Dear Mr. Brown:

On July 24, 2012, I received communication that the site located on State Route 78 at Bear Run Creek in Morgan County, Ohio is finished. The purpose of my communication was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of our discussion, the site was inactive and it appeared that construction activities had been completed. In accordance with the NPDES permit, a Notice of Termination (NOT) must be submitted to the Ohio Environmental Protection Agency (Ohio EPA) to release you from the terms and conditions of this permit.

A NOT may be submitted to Ohio EPA if the following requirements have been fulfilled:

1. A perennial vegetative cover (or equivalent means of stabilization) has been established over 100% of the surface area disturbed during construction. The vegetative growth must be at a growth density of 70%.

2. All temporary sediment and erosion controls have been removed and properly disposed.

3. All sediment has been permanently stabilized to prevent further erosion.

4. Construction activity at the site has ceased.

It appears that your site meets the above criteria. If you agree, please submit a NOT within 45 days of the completion of construction activities. Failure to submit a NOT is a violation of the permit requirements and may affect your ability to obtain a NPDES permit in the future. If your project has not yet begun or future phases of the project are planned please do not submit your NOT.

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov

Please send the completed NOT to the following address:

Ohio Environmental Protection Agency
Division of Surface Water
Storm Water Section
P.O. Box 1049
Columbus, Ohio 43216-1049

If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Sincerely,

Jennifer M. Witte for

Sara Peters
Storm Water Section
Division of Surface Water

SP/dh

Enclosure: Notice of Termination