



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Ashland County  
Lockwood Greene/Lockwood Station  
Construction  
Storm Water

August 29, 2012

Ms. Jeanne Kinney  
Lockwood Housing LLC  
229 Huber Village Boulevard  
Westerville, Ohio 43081

Dear Ms. Kinney:

On August 9, 2012, Tyler Leggett, Judson Delancey and Jessica Heitman inspected Lockwood Greene/Lockwood Station at Campbell Street and Vincent Street, Loudonville (photos taken). The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC01621\*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. No one was present onsite at the time of our visit.

It appeared that construction at the site was complete and the bare areas of the site had been seeded and had a grass cover. Finished buildings, paved drives and paved parking areas were present. It appeared that an extended detention pond had been installed as a post construction storm water management control to meet the permit requirements. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Ms. Jeanne Kinney  
August 29, 2012  
Page Two

Your site appears to meet the above requirements. If this is accurate and you have installed the post construction storm water management facilities required by the permit, please file the NOT form. The NOT form and instructions can be found on our website:

<http://www.epa.ohio.gov/dsw/storm/stormform.aspx>

NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

Within 10 days of the date on this letter, please submit a written description of how the post construction storm water management requirements will be met for this project. Your reply should include the type(s) of practices you are implementing and the basis for their design.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,



Lynette Hablitzel, P.E.  
Division of Storm Water  
Storm Water Program

/jlm

ec: Tracking