



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 26, 2012

Lisa Zigmund
ODOT District 6
400 East Williams Street
Delaware, OH 43015

Re: Notice of Termination Inspection at FRA-Scioto Bikeway Connector (PID 77591)/Franklin County Permit #: 4GC03778

Dear Mrs. Zigmund:

This letter is written in follow-up to a construction storm water inspection by Alicia Rector and Elizabeth Pleta of the Ohio EPA conducted at FRA-Scioto Bikeway Connector (PID 77591) located between Grandview Avenue and Dublin Road on July 16, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination will be required provided the post construction requirements are met. Please address the following:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm FRA Scioto bikeway Connector 7-16-2012



Figure 1 Silt fence requires maintenance



Figure 2 sediment controls required



Figure 3 Baron Areas