



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 26, 2012

William Harvey  
City of Bexley  
2242 E. Main Street  
Bexley, Ohio 43209

**RE: Storm Water Inspection at College Avenue Reconstruction – Franklin  
County Permit # 4GC03831\*AG**

Dear Mr. Harvey:

This letter is written in follow up to a construction storm water inspection by Brittany Turner and Jacqueline Sexton of the Ohio EPA, at College Avenue Reconstruction located on College Avenue from Livingston Avenue to East Main Street on July 16, 2012. The purpose of the inspection was to evaluate compliance with Ohio EPA General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Sediment and Erosion Controls:**

- Inlet protection must be established on the south end of the site or demonstrate an appropriate alternative. (See Figure 1 & 2)

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm College Avenue Reconstruction Franklin County 7-17-2012



Figure 1 Inlet protection required




Figure 2 Inlet protection required