



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 24, 2012

Re: Pike County
Beaver WWTP
Notice of Violation
OPA00088*ED; OH0041505
Correspondence (PWW)

Mayor and Council
Village of Beaver
P.O. Box 238
Beaver, Ohio 45613

Dear Mayor and Council:

We have reviewed your self-monitoring reports covering the months of January through June 2012 for the Village of Beaver Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	14.95	1/1/2012
001	00530	Total Suspended Solids	30D Qty	2.7	2.93625	1/1/2012
001	80082	CBOD 5 day	30D Conc	10	10.975	1/1/2012
001	00530	Total Suspended Solids	7D Conc	18	31.	1/8/2012
001	00530	Total Suspended Solids	7D Qty	4.1	5.11581	1/8/2012
001	80082	CBOD 5 day	7D Conc	15	31.5	1/8/2012
001	80082	CBOD 5 day	7D Qty	3.4	5.19832	1/8/2012
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	5.12	2/1/2012
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.70	.73013	2/1/2012
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	10.1	2/8/2012
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	1.0	1.42975	2/8/2012
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	5.16	3/1/2012
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	10.1	3/8/2012
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	1.0	1.21567	3/8/2012
001	80082	CBOD 5 day	7D Conc	15	17.	3/8/2012

* 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within 10 days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,

A handwritten signature in blue ink, appearing to read "Jack Knapp", written over a light blue horizontal line.

Jack Knapp
District Representative
Division of Surface Water

JK/dh

c: Ronald Aldrich, Operator