



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 24, 2012

Re: Hocking County
Old Man's Cave Chalets
Notice of Violation
0PR00114*CD; OH0115312
Correspondence (PWW)

Mr. Mark Devol, Owner
Old Man's Cave Chalets
18905 State Route 664 South
Logan, Ohio 43138

Dear Mr. Devol:

We have reviewed your self-monitoring reports covering the months of January through June of 2012 for the Old Man's Cave Chalets Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	4.6	1/1/2012
001	80082	CBOD 5 day	30D Conc	10	10.6	1/1/2012
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	4.5	4.6	1/18/2012
001	00530	Total Suspended Solids	30D Conc	12	15.	3/1/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	5/4/2012
001	31648	E. coli	30D Conc	161	4800.	6/1/2012
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	5.8	6/1/2012
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.019	.0483	6/1/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	4.1	6/12/2012
001	00300	Dissolved Oxygen	1D Conc	6.0	5.9	6/15/2012
001	31648	E. coli	7D Conc	362	4800.	6/22/2012
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	5.8	6/28/2012
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.028	.0483	6/28/2012

* 7 D Conc is equal to average weekly concentration limit.
* 30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within 10 days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a response has been sent prior to this letter, no further action is required.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

c: Rick Verhotz, Operator