



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 24, 2012

Re: Ross County
Huntington LSD
Notice of Violation
OPT00007*GD; OH0048607
Correspondence (PWW)

Mr. Jerry Mowery, Superintendent
Huntington Local School District
188 Huntsman Drive
Chillicothe, Ohio 45601

Dear Mr. Mowery:

We have reviewed your self-monitoring reports covering the months of January through June of 2012 for the Huntington Local School District Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	.019	.08	5/10/2012
001	50060	Chlorine, Total Residual	1D Conc	.019	.05	6/21/2012

* 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a response has been sent prior to this letter no further action is required.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,

Jack Knapp
District Representative
Division of Surface Water

JK/dh