



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 2, 2012

Rob Maloney  
Jerome Village Community Authority  
375 N Front Street Suite 200  
Columbus, OH 43215

**Re: Storm Water Inspection at Jerome Village:  
Ryan Parkway Public Street Improvements  
Permit Number: 4GC03844\*AG**

Dear Mr. Maloney:

This letter is written regarding the joint inspection I conducted with Elizabeth Pleta, Alicia Rector, and Cole Miller of the Ohio EPA, at Jerome Village: Ryan Parkway Public Street Improvements located at West of Jerome Road between Brock Road and Wells Road on July 24, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Sediment and Erosion Controls**

- During the inspection, I noted the extensive perimeter controls installed on site. Please ensure all controls are properly maintained as the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- During the inspection, I noted a bleeder channel with intentions of draining the site (See Figure 1). Please eliminate this channel and route all affective areas to the centralized basin intended for treatment.
- The detention basin noted onsite must be modified to address sediment control via the installation of a temporary riser. This will allow for additional settling time for the suspended solids to settle prior to a final discharge from the site.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Rob Maloney  
Jerome Village Community Authority  
Page 2

The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office



**Figure 1 Elimination of bleeder ditch required.**