



Environmental Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 30, 2012

Mr. Billy Slaven  
City of Hamilton  
2451 River Road  
Hamilton, Ohio 45011

**RE: Butler County, Hamilton WWTP, NPDES Permit Violations**

Dear Mr. Slaven:

We have reviewed your Discharge Monitoring Reports covering the month of July 2012 for the referenced facility. Our review indicates a violation of the condition of your NPDES Permit (NPDES Permit # OH0025445; OEPA Permit # 1PE00002\*MD). The specific instance of noncompliance was as follows:

Effluent Limit Violations for July 2012

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
July 2012	Chlorine	Daily	mg/l	0.037	0.29

Please be advised that failure to comply with the effluent of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reason for the above violation and the action being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle  
Environmental Specialist  
Division of Surface Water  
Permit Section

NS/tf