



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 21, 2012

RE: ASHTABULA COUNTY
DORSET TOWNSHIP
COMP DAIRY FARMS, LTD
NPDES PERMIT NO: OHC000003
OHIO EPA PERMIT NO: 3GC04810*AG
CONSTRUCTION STORM WATER INSPECTION

Bruce Bailey
Comp Dairy Farm Ltd.
3015 Allen Comp Road
Dorset, Ohio 44032

Dear Mr. Bailey:

On July 24, 2012, Ohio EPA conducted an inspection of the Comp Dairy Farms, LTD, located at 3015 Allen Comp Road, Dorset Township, Ashtabula County (site). Ohio EPA records indicate that the site is covered by General National Pollutant Discharge Elimination System Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04810*AG.

The inspection documented that construction activities at the site appear to have been completed. Part IV.B.2. of the General Storm Water Permit requires a Notice of Termination (NOT) form, enclosed, to be submitted for the site within 45 days of completing all permitted land disturbance activities.

Within fourteen days of receiving this inspection letter, you must perform one of the following actions:

1. Submit the following information to Ohio EPA:
 - A. Documentation (water quality volume calculations, engineered plans, etc.) on how the site has satisfied the post-construction storm water management requirements established within Part III.G.2.e of the General Storm Water Permit;
 - B. Documentation that all sediment control practices (i.e. installed silt fence) have been removed from the site. During the inspection, Ohio EPA documented that silt fence installed in areas where the site has been permanently stabilized; and
 - C. A completed NOT form, in accordance with the enclosed instructions, if final stabilization has been achieved on all portions of the site. The General Storm Water Permit defines final stabilization as "all soil disturbing activities at the site are complete and a uniform perennial vegetative cover (e.g., evenly distributed, without large bare areas) with a density of at least 70 percent cover for the area has been established on all unpaved areas and areas not covered by permanent structures or equivalent stabilization measures (such as the use of landscape mulches, rip-rap, gabions or geotextiles) have been employed. In addition, all temporary erosion and sediment control practices are removed and disposed of

and all trapped sediment is permanently stabilized to prevent further erosion.”
For your convenience, the NOT form can be obtained from the following website:

<http://www.epa.ohio.gov/dsw/storm/stormform.aspx>; or

2. Submit written correspondence that states construction activities have not been completed on the site and the General Storm Water Permit will remain effective. Please provide a revised schedule for when construction activities are expected to commence and terminate.

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via e-mail at chris.moody@epa.ohio.gov.

Sincerely,



Chris Moody
Environmental Specialist II
Division of Surface Water

CM/cs

Ec: Bruce Bailey, Quasar Energy Group