



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

September 4, 2012

**Re:** Muskingum County  
Gorsky Equipment, Inc.  
Storm Water Construction Activity  
OGC00230\*AG

Mr. Frank Gorsky  
Gorsky Trucking, Inc.  
3795 Frazeyburg Road  
Zanesville, Ohio 43701

Dear Mr. Gorsky:

On July 30, 2012, I visited the site located on Olde Falls Road and State Route 60 in Zanesville, Ohio. The purpose of my site visit and inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of my inspection, the site was inactive and it appeared that construction activities had been completed. In accordance with the NPDES permit, a Notice of Termination (NOT) must be submitted to the Ohio Environmental Protection Agency (Ohio EPA) to release you from the terms and conditions of this permit.

A NOT may be submitted to Ohio EPA if the following requirements have been fulfilled:

1. A perennial vegetative cover (or equivalent means of stabilization) has been established over 100% of the surface area disturbed during construction. The vegetative growth must be at a growth density of 70%.
2. All temporary sediment and erosion controls have been removed and properly disposed.
3. All sediment has been permanently stabilized to prevent further erosion.
4. Construction activity at the site has ceased.

It appears that your site meets the above criteria. If you agree, please submit a NOT within 45 days of the completion of construction activities. Failure to submit a NOT is a violation of the permit requirements and may affect your ability to obtain a NPDES permit in the future. If your project has not yet begun or future phases of the project are planned please do not submit your NOT.

Please send the completed NOT to the following address:

Ohio Environmental Protection Agency  
Division of Surface Water  
Storm Water Section  
P.O. Box 1049  
Columbus, Ohio 43216-1049

If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in blue ink that reads "Jennifer M. Wottle for". The signature is written in a cursive style.

Sara Peters  
Storm Water Section  
Division of Surface Water

SJP/dh

Enclosure: Notice of Termination