



**Environmental  
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

August 22, 2012

**Re:** Washington County  
Washington Electric Cooperative  
Storm Water Construction Activity  
0GC01549\*AG

Mr. Jerry Zalmanek  
440 Highland Ridge Road  
Marietta, Ohio 45750

Mr. Mark Mondo  
27620 S.R. 7  
P.O. Box 250  
Reno, Ohio 45773

Dear Mr. Mondo and Mr. Zalmanek:

On July 12, 2012, I visited the site located on the 360 Highland Ridge Road located in Marietta, Ohio. The purpose of my site visit and inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of my inspection, the site was inactive and it appeared that construction activities had been completed. In accordance with the NPDES permit, a Notice of Termination (NOT) must be submitted to the Ohio Environmental Protection Agency (Ohio EPA) to release you from the terms and conditions of this permit.

**Please take down the silt fencing at the 440 Highland Ridge Road Facility.**

A NOT may be submitted to Ohio EPA if the following requirements have been fulfilled:

1. A perennial vegetative cover (or equivalent means of stabilization) has been established over 100% of the surface area disturbed during construction. The vegetative growth must be at a growth density of 70%.
2. All temporary sediment and erosion controls have been removed and properly disposed.
3. All sediment has been permanently stabilized to prevent further erosion.
4. Construction activity at the site has ceased.


It appears that your site meets the above criteria. If you agree, please submit a NOT within 45 days of the completion of construction activities. Failure to submit a NOT is a violation of the permit requirements and may affect your ability to obtain a NPDES permit in the future. If your project has not yet begun or future phases of the project are planned please do not submit your NOT.

Please send the completed NOT to the following address:

Ohio Environmental Protection Agency  
Division of Surface Water  
Storm Water Section  
P.O. Box 1049  
Columbus, Ohio 43216-1049

If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in blue ink, appearing to read "Sara Peters" with a flourish underneath. The word "for" is written in smaller letters below the main signature.

Sara Peters  
Storm Water Section  
Division of Surface Water

SP/dh

Enclosure: Notice of Termination