



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

RE: **Notice of Violation**
Auglaize County
Waynesfield WWTP
Ohio EPA Permit No. 2PB00022
NPDES Permit No. OH0028029

August 31, 2012

Mr. Ronald Suter
Wastewater Operator
Village of Waynesfield
P.O. Box 476
Waynesfield, Ohio 45896

Dear Mr. Suter:

We are in receipt of your self-monitoring reports covering the months of April through June 2012 for the above referenced facility. Our review indicates violations of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of non-compliance are enclosed on a separate sheet. Further review of your self-monitoring reports for the previous six months, ending in June 2012, indicates that you are in significant non-compliance (SNC) with two effluent limitations contained in your NPDES permit. The specific instances of SNC are enclosed on a separate sheet.

Within 10 days of the date of this letter, please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

As stated in our previous letter, we have received and reviewed the Village's proposed project schedule for wastewater treatment plant (WWTP) improvements submitted by Mr. Fred Rowe. This schedule will be included in the Village's upcoming NPDES permit renewal. Be advised that if that schedule is not carried out in a timely manner or if a completion date is missed, we will recommend that the Director of Ohio EPA take an enforcement action against the Village to bring the WWTP into compliance with Ohio law.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,

Justin A. Williams
Environmental Specialist II
Division of Surface Water

/jlm
Enclosures
ec: NOV Tracking

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

Get New Data

Violations for Waynesfield WWT - April - June 2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00022*KD	April 2012	001	00530	Total Suspended Solids	30D Conc	30	86.	4/1/2012
2PB00022*KD	April 2012	001	00530	Total Suspended Solids	30D Qty	14.0	29.1681	4/1/2012
2PB00022*KD	April 2012	001	80082	CBOD 5 day	30D Conc	20	27.75	4/1/2012
2PB00022*KD	April 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.3	4/3/2012
2PB00022*KD	April 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.2	4/4/2012
2PB00022*KD	April 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.2	4/5/2012
2PB00022*KD	April 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	4/6/2012
2PB00022*KD	April 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	4/7/2012
2PB00022*KD	April 2012	001	00530	Total Suspended Solids	7D Conc	45	96.	4/8/2012
2PB00022*KD	April 2012	001	00530	Total Suspended Solids	7D Qty	21.0	23.2550	4/8/2012
2PB00022*KD	April 2012	001	80082	CBOD 5 day	7D Conc	30	33.	4/8/2012
2PB00022*KD	April 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	4/13/2012
2PB00022*KD	April 2012	001	00530	Total Suspended Solids	7D Conc	45	97.	4/15/2012
2PB00022*KD	April 2012	001	00530	Total Suspended Solids	7D Qty	21.0	44.7916	4/15/2012
2PB00022*KD	April 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	4/16/2012
2PB00022*KD	April 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.8	4/17/2012
2PB00022*KD	April 2012	001	00400	pH	1D Conc	9.0	9.2	4/18/2012
2PB00022*KD	April 2012	001	00300	Dissolved Oxygen	1D Conc	5.0	4.	4/18/2012
2PB00022*KD	April 2012	001	00400	pH	1D Conc	9.0	9.5	4/19/2012
2PB00022*KD	April 2012	001	00530	Total Suspended Solids	7D Conc	45	110.	4/22/2012
2PB00022*KD	April 2012	001	00530	Total Suspended Solids	7D Qty	21.0	42.8840	4/22/2012
2PB00022*KD	April 2012	001	00400	pH	1D Conc	9.0	9.5	4/23/2012
2PB00022*KD	April 2012	001	00400	pH	1D Conc	9.0	9.6	4/24/2012
2PB00022*KD	April 2012	001	00400	pH	1D Conc	9.0	9.7	4/25/2012
2PB00022*KD	April 2012	001	00400	pH	1D Conc	9.0	9.3	4/27/2012
2PB00022*KD	May 2012	001	00530	Total Suspended Solids	30D Conc	30	43.75	5/1/2012
2PB00022*KD	May 2012	001	00530	Total Suspended Solids	7D Conc	45	67.	5/22/2012
2PB00022*KD	May 2012	001	00530	Total Suspended Solids	7D Qty	21.0	21.5555	5/22/2012
2PB00022*KD	June 2012	001	00530	Total Suspended Solids	30D Conc	30	62.	6/1/2012
2PB00022*KD	June 2012	001	00530	Total Suspended Solids	30D Qty	14.0	18.0336	6/1/2012
2PB00022*KD	June 2012	001	00530	Total Suspended Solids	7D Qty	21.0	38.6827	6/1/2012
2PB00022*KD	June 2012	001	80082	CBOD 5 day	7D Qty	10.7	15.1967	6/1/2012
2PB00022*KD	June 2012	001	01119	Copper, Total Recovera	30D Qty	0.013	.0221	6/1/2012
2PB00022*KD	June 2012	001	01119	Copper, Total Recovera	1D Qty	0.021	.0221	6/6/2012
2PB00022*KD	June 2012	001	00530	Total Suspended Solids	7D Conc	45	52.	6/8/2012
2PB00022*KD	June 2012	001	00530	Total Suspended Solids	7D Qty	21.0	31.2943	6/8/2012
2PB00022*KD	June 2012	001	00530	Total Suspended Solids	7D Conc	45	130.	6/15/2012

Get New
Data

Get Detail
for Selected
Permit

Facilities in Significant Non-Compliance **

Period: Jan-12 Jun-12

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max % Exceed	# Months Signif Exceed (1)**	# Months Exceed (2)**
Auglaize	2PB00022	Waynesfield WWTP		1	00530	Total Suspended Solids	199.4	4	4
Auglaize	2PB00022	Waynesfield WWTP		1	80082	CBOD 5 day	108.8	3	4