



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 28, 2012

RE: HENDRICKSON RESEARCH & DEVELOPMENT  
3IN00379\*AX (INDIVIDUAL PERMIT)  
3GR00249\*DG(STORMWATER)  
STARK COUNTY

Frank Hezoucky  
Project Manager  
Hendrickson Research & Development  
2070 Industrial Place SE  
Canton, Ohio 44707-2641

Dear Mr. Hezoucky:

On August 16, 2012 this writer conducted an inspection of your facility for the purpose of gathering information to draft your initial NPDES Permit. You as well as Mike Rinaldi, Hendrickson, were present during the visit. The following is a summary of the inspection:

**General**

Hendrickson performs research and development specific to testing, analyzing and prototype development of heavy duty commercial trailer suspension systems and related components. This is not a full scale manufacturing facility. Potable and process water is provided by the City of Canton, which also provides sanitary sewers.

**Wastewater Generated**

The only wastewaters proposed to be discharged are once thru non-contact cooling water (nccw) and City water used to fill new tanker vessels when performing weight testing. Both discharges will be sporadic. The NCCW will only be used to supplement a propylene glycol closed loop cooling system to cool hydraulic testing equipment. It is anticipated that it will only be discharged during hot summer months. The clean tanker water is anticipated to be discharged on to ten times per year at 8,000 gallons per event.

Any other wastewaters generated will be directed to the City of Canton sanitary sewers.

Your facility also is regulated under the new Multi Sector General Permit (MSGP). It appears that your SIC Code is 3711 with your Sector Specific Requirements listed in Part 8, Subpart AB. This sector does not require specific Best Management Practices nor Benchmark monitoring. All other requirements of the permit apply. On the day of my inspection, you would not qualify for the No Exposure Certification, as there were drums of waste oil being stored outside and open top dumpsters containing solid waste.

I trust that the above is an accurate account of the inspection. If you should have any questions, feel free to contact this writer at (330) 963-1136 or by e-mail at [phil.rhodes@epa.state.oh.us](mailto:phil.rhodes@epa.state.oh.us).

Sincerely,

Philip P. Rhodes, P.E  
Environmental Specialist II  
Division of Surface Water

PPR/cs

File: Industrial Permit Compliance  
Industrial Storm water

Northeast District Office  
2110 East Aurora Road  
Twinsburg, OH 44087-1924

330 | 963 1200  
330 | 487 0769 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)