



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Sandusky County
Area Aggregates - Olen Corporation
NPDES Permit 2IJ00097

September 12, 2012

Mr. Chris Wagner
Operations Manager
The Olen Corporation
4755 South High Street
Columbus, Ohio 43207-4080

Dear Mr. Wagner:

On April 26, 2012, an inspection of the Area Aggregates - Olen Corporation (State Route 20) wastewater treatment plant (WWTP) was made. Mr. Tom Kurfis, Clean Water Services (CWS) Operator, was present and provided information regarding wastewater treatment.

Observations noted during the inspection of the WWTP are as follows:

- The plant was operating and had what appeared to be adequate aeration at the time of the inspection.
- The sludge return was operational and the skimmer is operated as needed.
- No clarifier effluent weir is provided. An effluent weir should be installed.
- Disinfection must be provided from May through October.
- The required operator log book was on site.

A review of your Discharge Monitoring Reports (DMR) shows the following permit violation:

January 2011 thru July 2012								
Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date	
March 2011	003	00530	Total Suspended Solids	30D Conc	12.0	18.	3/1/2011	
March 2011	003	80082	CBOD 5 day	30D Conc	10.0	11.	3/1/2011	
June 2011	003	00530	Total Suspended Solids	30D Conc	12.0	13.	6/1/2011	
Dec. 2011	003	00530	Total Suspended Solids	30D Conc	12.0	13.	12/1/2011	

If there are any questions, please contact me at 419-373-3014.

Yours truly,


Mary Beth Cohen
Division of Surface Water

/jlm
Enclosure

cc: Tom Kurfis, Clean Water Services, Inc.
Tracking

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov



State of Ohio Environmental Protection Agency
Northwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
2PIJ00097	OH0135488	04/26/2012	C	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Area Aggregates – Olen Corp 873 E. Main St Woodville, OH 43469	9:30 a.m.	August 1, 2012
	Exit Time	Permit Expiration Date
	10:00 a.m.	July 31, 2017
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Tom Kurfis, Operator – CWS	419-352-6870	
Name, Address and Title of Responsible Official	Phone Number	
Mr. Chris Wagner, Operations Manager The Olen Corporation 4755 S. High Street Columbus, OH 43207-4080	800-491-6536	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	N	Flow Measurement	N	Pretreatment
M	Records/Reports	N	Laboratory	N	Compliance Schedule
M	Operations & Maintenance	N	Effluent/Receiving Waters	N	Self-Monitoring Program
M	Facility Site Review	N	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
<p><i>A clarifier effluent weir should be provided.</i></p>	
Inspector	Reviewer
 Mary Beth Cohen Division of Surface Water Northwest District Office	 Thomas Poffenbarger, P.E. Water Quality Engineer II/Unit Supervisor Division of Surface Water Northwest District Office
9/11/12 Date	9/12/12 Date