



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Sandusky County
Area Aggregates - Olen Corporation
NPDES Permit 2IJ00028

September 11, 2012

Mr. Chris Wagner
Operations Manager
The Olen Corporation
4755 South High Street
Columbus, Ohio 43207-4080

Dear Mr. Wagner:

On April 26, 2012, an inspection of the Area Aggregates - Olen Corporation (Anderson Road facility) wastewater treatment plant (WWTP) was made. Mr. Tom Kurfis, Clean Water Services (CWS) Operator, and Jim Bishoff, were present and provided information regarding wastewater treatment.

Observations noted during the inspection of the WWTP are as follows:


- The plant was operating and had what appeared to be adequate aeration at the time of the inspection.
- The sludge return was operational and the skimmer is operated as needed.
- The clarifier effluent weir does not include a baffle. An effluent weir should be installed.
- Disinfection must be provided from May through October.
- The required operator log book was on site.

A review of your Discharge Monitoring Reports (DMR) shows the following permit violation:

Reporting Period	Station	Reporting Code	January 2011 thru July 2012		Reported Value	Violation Date	
			Parameter	Limit Type			
March 2011	601	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	2.3	3/1/2011
March 2011	601	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	2.3	3/1/2011

If there are any questions, please contact me at 419-373-3014.

Yours truly,


Mary Beth Cohen
Division of Surface Water

/jlm
Enclosure
pc: Tom Kurfis, Clean Water Services, Inc.
ec: Tracking



State of Ohio Environmental Protection Agency
Northwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
2PIJ00028	OH0002500	04/26/2012	C	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Area Aggregates – Olen Corp 659 Anderson Road Woodville, OH 43469	9:00 a.m.	February 1, 2011
	Exit Time	Permit Expiration Date
	9:30 a.m.	January 31, 2016
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Tom Kurfis, Operator – CWS Jim Bishoff, Area Aggregates	419-352-6870 419-849-3218	
Name, Address and Title of Responsible Official	Phone Number	
Mr. Chris Wagner, Operations Manager The Olen Corporation 4755 S. High Street Columbus, OH 43207-4080	800-491-6536	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	N	Flow Measurement	N	Pretreatment
M	Records/Reports	N	Laboratory	N	Compliance Schedule
M	Operations & Maintenance	N	Effluent/Receiving Waters	N	Self-Monitoring Program
M	Facility Site Review	N	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
<p>A clarifier effluent weir should be provided.</p>	
Inspector	Reviewer
Mary Beth Cohen <i>MBC</i> Division of Surface Water Northwest District Office	Thomas Poffenbarger, P.E. <i>Thomas Poffenbarger</i> Date Water Quality Engineer II/Unit Supervisor Division of Surface Water Northwest District Office
Date 9/11/12	Date 9/12/12