



**Environmental
Protection Agency**

2009-2011 Governor
2007-2009 Lt. Governor
2002-2005 Director

September 6, 2012

Mike Haughton
Rolls Royce Energy Systems Inc.
105 North Sandusky Street
Mount Vernon, Ohio 43050

**Re: Storm Water Inspection at Rolls Royce Energy Systems Inc. / Knox County
Permit Number: 4GC03814*AG**

Dear Mr. Haughton:

This letter is written in follow-up to a construction storm water inspection by Brittany Turner of the Ohio EPA, at Rolls Royce Energy Systems Inc. located at 105 North Sandusky Street on August 21, 2012. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- Our staff observed an area of concrete disposal that lacked proper containment (See Figure 1). If future onsite disposal is required, containment measures such as a pit impoundment is expected.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Rolls Royce Systems Inc. Knox County 8-22-2012



Figure 1 Concrete washout must be established