



**Environmental
Protection Agency**

John Kasich, Governor
Mike DeWine, Lt. Governor
Mark Lese, Director

September 6, 2012

Tom Anderson
Menards Inc.
5101 Menards Drive
Eau Claire Wisconsin, Ohio 54703

Re: Storm Water Inspection Concerning Activities Associated with Construction on Menards Drive—Permit#: 4GCO00075*AG

Dear Mr. Anderson:

This letter is written regarding the storm water inspection I conducted by at Menards in Delaware County on August 21, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment Erosion Controls:

During the inspection, I noted the initial installation of the perimeter silt fence associated with construction of this site. The perimeter silt fence appears to be installed correctly and must be maintained in accordance with the General Storm Water Permit.

Please note the General Storm Water Permit and your approved Storm Water Pollution Prevention Plan (SWPPP) mandates the installation of a centralized sediment basin next in the construction sequence. The central basin must be sized in accordance with the requirements of the General Permit. Perimeter diversions and/or ditches are expected to direct all affected areas to the basins intended for sediment control prior to the storm sewer installation.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Menards Delaware County 8-312012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov