



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Sandusky County  
Woodbridge Corporation  
Industrial Storm Water

September 13, 2012

Mr. Matt Haas  
Woodbridge Corporation  
HSE/HR Coordinator  
527 Graham Drive  
Fremont, Ohio 43420-4077

Dear Mr. Haas:

On August 21, 2012, a storm water compliance inspection was made of Woodbridge Corporation in the City of Fremont, Sandusky County, to determine compliance with the National Pollutant Discharge Elimination System (NPDES) General Permit for Storm Water Associated with Industrial Activity (IGP) issued to Woodbridge Corporation. The inspection consisted of a tour of the grounds outside of this facility and a review of the Stormwater Pollution Prevention Plan (SWP3).

Woodbridge Corporation manufactures foam automobile seat components. Woodbridge Corporation has a Standard Industrial Classification of 3086 and is regulated under section Y of the IGP. Observations of the outside inspection include rooftop emissions equipment, storage of metal containers outside, and the acid receiving area. Storm water from the acid receiving area is contained and collected in a valved container. Discharge of the storm water is done periodically to a swale on the property. I recommend that a visual inspection is done whenever this storm water is discharged.

A review of the SWP3 shows that the SWP3 needs to be updated and recertified and the quarterly inspection forms need to be updated. Quarterly inspections, which include a visual inspection of the discharge of storm water, are to be documented and kept with the SWP3.

If you have any questions, you may contact me at (419) 373-3016 or by e-mail at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us).

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/jlm

ec: Tracking