



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
John P. Blyler, Director

September 6, 2012

Richard Long
Taylor Road Storage
7821 Taylor Road,
Reynoldsburg, OH 43068

**Re: Storm Water Inspection Concerning Construction Activities Associated with
Taylor Road Storage in Reynoldsburg, Ohio—Permit #: 4GC03588*AG**

Dear Mr. Long,

This letter is written regarding the storm water inspection I conducted at Taylor Road Storage on August 21, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment Erosion Controls:

- During the inspection, I noted the current excavation is presently containing storm water runoff from the site. This is an acceptable alternative to implementing sediment controls concurrent with this phase of construction. Please note once off site positive drainage is established, alternate controls such as perimeter silt fence, are required.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Richard Long
Taylor Road Storage
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office