



**Environmental  
Protection Agency**

John Kasich, Governor  
Robert Cordusio, Lt. Governor  
David B. Clark, Director

September 17, 2012

Al Coughlin  
Coughlin Enterprises  
71 E Wilson Bridge Rd  
Worthington, OH 43085

**Re: Storm water inspection at Coughlin Automotive / Licking County  
Permit #4GC01147\*AG**

Dear Mr. Coughlin:

This letter is written regarding the storm water inspection I conducted at Coughlin Automotive on September 10, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

- I noted the recent dewatering associated with the large centralized impoundment for this site. I understand that post-construction modifications as well as sediment control modifications were imposed on this basin intended for treatment during and following construction activities. It appears that the seal to the temporary riser is compromised as the significant lowering of the water level is evident. Please implement appropriate measures to reestablish the appropriate storage volume to continue compliance with the permit.
- In addition please provide me any update with respect to the implementation of your post-construction measures associated with this impoundment.


**Winter Month Onset:**

- Please be aware measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected. This would include but not limited to a crimped straw mulch cover. Please submit to my attention the temporary seeding/protection schedule to ensure the erosion protection requirements are not violated.

Al Coughlin  
Coughlin Enterprises  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (***email preferred***) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

A handwritten signature in black ink, appearing to read 'H. Kallipolitis', written over a faint circular stamp or watermark.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office