



**Environmental
Protection Agency**

John Kasich, Governor
Paul Taylor, Lt. Governor
Robert Smith, Director

September 18, 2012

Patti Neal
Carter USA
171 17th Street, Suite 1200
Atlanta, GA 30363

**RE: Storm Water Inspection at Columbus Commons Mixed Use Development / Franklin
County Permit #4GC03913*AG**

Dear Mrs. Neal:

This letter is written regarding the storm water inspection I conducted of the construction activities located at 160 South High Street on September 13, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls

- I noted the installation of straw waddles at the base of the slope however I am concerned that this will not be adequate to minimize sediment loss from the project. I will continue to monitor the sediment transport from the site and I recommend additional measures such as a linear silt fence in parallel with the existing straw waddle.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Ohio EPA

HK/slwr Columbus Commons Mixed Use Development 9-13-12.doc