



John R. Kasich, Governor  
 Mary Taylor, Lt. Governor  
 Scott J. Nally, Director

October 15, 2012

Mr. Lonnie Snow, Regional Manager  
 Hueston Woods State Park  
 6301 Park Office Road  
 College Corner, Ohio 45003

**RE: Notices of Violation  
 Hueston Woods State Park WWTPs, NPDES Permits 1PP00002, 1PP00004  
 and 1PP00005**

Dear Mr. Snow:

We have received your self-monitoring report covering the months of March 2011 through August 2012 for the referenced facilities. Our review indicates violations of the conditions of your NPDES permits. The specific instances of noncompliance and/or deficiencies are as follows:

**Numerical Violations 1PP00002**

Station	Code	Parameter	Permit Limit	Reported	Date
001	00610	NH3	2.0	4.155	7/1/2011
001	00610	NH3	3.0	8.31	7/1/2011
001	00610	NH3	0.38	.99078	7/1/2011
001	00610	NH3	0.57	1.9816	7/1/2011
001	31616	Fecal Coliform	200	550.	7/1/2011
001	31616	Fecal Coliform	400	550.	7/1/2011
001	00610	NH3	3.0	3.61	10/15/2011
001	00530	TSS	18	24.	11/8/2011
001	00610	NH3	2.0	4.525	5/1/2012
001	00610	NH3	3.0	9.05	5/15/2012
001	00610	NH3	2.0	2.43	6/1/2012
001	00610	NH3	3.0	4.86	6/1/2012
001	80082	CBOD 5 day	10	15	6/1/2012
001	31616	Fecal Coliform	400	500.	6/8/2012
001	80082	CBOD 5 day	15	60.	6/22/2012

Mr. Lonnie Snow, Regional Manager  
Hueston Woods State Park  
October 15, 2012  
Page 2

#### Frequency Violations 1PP00002

Station	Code	Parameter	Permit Limit	Expected	Reported	Date
001	00530	TSS	1/Week	1	0	6/15/2011
001	80082	CBOD 5	1/Week	1	0	6/15/2011
001	00400	pH	1/Week	1	0	6/15/2011
001	00300	D.O.	1/Week	1	0	6/15/2011

#### Numerical Violations for 1PP00004

Station	Code	Parameter	Permit Limit	Reported	Date
001	00300	D.O.	6.0	5.	8/25/2011

#### Numerical Violations for 1PP00005

Station	Code	Parameter	Permit Limit	Reported	Date
001	31616	Fecal Coliform	400	510	6/8/2012
001	31616	Fecal Coliform	200	200	8/1/2012

Ohio EPA's records indicate that the Hueston Woods State Park Beach/Marina, permit 1PP00002, is in Significant Non-Compliance (SNC) due to ammonia violations. Ohio EPA acknowledges that PTIs already submitted and yet to be submitted for improvements at the Hueston Woods State Park should eventually address the problems at the WWTPs. However, Ohio EPA needs a definitive date regarding when a PTI will be submitted for the last phase of the improvements that will include the upgrades to the Beach/Marina WWTP with connection of the Lodge/Cabin WWTP collection system to the upgraded Beach/Marina WWTP.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please inform this office, in writing, by October 29, 2012 as to the reason for the violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Mr. Lonnie Snow, Regional Manager  
Hueston Woods State Park  
October 15, 2012  
Page 3

If you have any questions regarding the above, please contact me at this office.

Respectfully,

A handwritten signature in black ink, appearing to read "Maureen M. Ware", with a long horizontal flourish extending to the right.

Maureen M. Ware  
Environmental Specialist  
Division of Surface Water

MMW/tf

ec: Preble County Health Department