



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 11, 2012

Steve Williamson
6000 Riverside Drive
Columbus, Ohio 43017

Re: Storm Water Inspection Concerning Construction Activities Associated with Friendship Village in Franklin County—Permit #: 4GC03231*AG

Dear Mr. Williamson:

This letter is written regarding the storm water inspection I conducted at Friendship Village on Riverside Drive in Franklin County on September 24, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment Erosion Controls:

- The perimeter sediment controls associated with this site will require continued maintenance. Please ensure maintenance is provided for all sediment erosion controls via your required self-inspections every seven (7) days or within 24 hours of a precipitation event equal to or greater than half an inch. A log of all inspections must be maintained on site and available for review.
- Please be aware measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected. This would include but not limited to a crimped straw mulch cover. Please submit to my attention the temporary seeding/protection schedule to ensure the erosion protection requirements are not violated.

Post Construction:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kailipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Steve Williamson
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (***email preferred***) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

A handwritten signature in black ink, appearing to read 'H. Kallipolitis', with a long horizontal stroke extending to the right.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Riverside Villas