



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 16, 2012

Re: Muskingum County
Wellington Place
Storm Water Construction Activity
Notice of Violation
0GC00667*AG

Mr. Andy Walther
Stoneworks LLC
2052 Cherry Valley Road
Newark, Ohio 43055

Dear Mr. Walther:

On June 26, 2012, I visited your site Wellington Place. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance.
2. Part III.G.2.b.ii. of the permit states that operators shall stabilize channels and outfalls to prevent erosive flows. Techniques may include seeding, mulching, erosion control matting, sodding, rip rap, or rock check dams.

The site did not meet the above requirements. Stabilize the site to meet the above requirements immediately.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in black ink, appearing to be 'A Wolfe', written in a cursive style.

Aaron Wolfe
Storm Water Section
Division of Surface Water

AW/dh