



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 15, 2012

Mr. David Baril, Club Manager
Brown's Run Country Club
6855 Sloebig Road
Middletown, Ohio 45042

RE: Butler County, Brown's Run Country Club, NPDES Permit Violations

Dear Mr. Baril:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of July through September 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit (NPDES Permit # OH0085669; OEPA Permit # 1PR00002*BD). The specific instances of noncompliance and deficiencies are as follows:

Effluent Violations for July through September 2012

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
August 2012	TSS	Monthly	mg/l	12	18

Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please inform this office, in writing, by October 31, 2012, as to the reason for the above referenced violation, as well as a description of the action taken or proposed to prevent any further violation. Your response should include the dates, either actual or proposed, for completion of the action. Future violations must be reported as required by the NPDES permit as detailed in Part III.12 titled "Noncompliance Notification".

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle
Environmental Specialist
Division of Surface Water
Permit Section