



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 21, 2012

Matt Weber
City of Delaware
Engineering Dept.
20 E. William Street
Delaware, OH 43015

**Re: Storm Water Inspection at Smith Park Site Improvements
Delaware County / Permit Number: 4GCO00064*AG**

Dear Mr. Weber:

This letter is written in follow-up to a construction storm water inspection by Kelsey Heyob and Katie Rumora of the Ohio EPA, at Smith Park Site Improvements located on Troy Road in Delaware, Ohio on July 10, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- All areas adjacent to the trail, as noted in Figure 1, must be protected from erosion within seven days of receipt of this letter.
- The silt fence associated with all outlying areas not directed to the sediment pond requires maintenance at this time. **(See Figures 2-4)**
- Sediment controls must be installed on all storm drains to minimize sediment laden water from entering waters of the state.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Matt Weber
City of Delaware
Engineering Dept.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

A handwritten signature in black ink, appearing to read "Harry Kallipolitis", written in a cursive style.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office




Figure 3: Maintain silt fence.

Figure 4: Maintain silt fence.




Figure 6: Requires sediment controls.




Figure 5: Requires sediment control.



Figure 1: Stabilization required along park trail.




Figure 2: Maintain silt fence.