



**Environmental  
Protection Agency**

**John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director**

August 14, 2012

Harry Gulley, HSE Manager  
Aleris Rolled Products Inc.  
1 Reynolds Road  
Ashville, OH 43103

**Re: Aleris Rolled Products Inc.  
NPDES Permit 4IC00002/ OH0003891  
Reconnaissance Inspection  
Pickaway County**

Dear Mr. Gulley:

On August 7, 2012, a Reconnaissance Inspection was conducted at Aleris Rolled Products Inc. Present for the inspection were Eric Kellough and yourself representing Aleris Rolled Products, Inc. and myself of the Ohio EPA, Central District Office, Division of Surface Water.

The purpose of the inspection was to evaluate compliance with the terms and conditions of your NPDES permit and to evaluate the operation and maintenance of the plant. The findings of the inspection are listed in the attachment to this letter. There were no significant problems or violations noted during the inspection.

If you have any questions or comments concerning the enclosed inspection report, please contact me at (614) 728-3854 or e-mail at [paul.vandermeer@epa.ohio.gov](mailto:paul.vandermeer@epa.ohio.gov).

Sincerely

Paul L. Vandermeer  
Environmental Specialist  
Compliance and Enforcement Unit  
Division of Surface Water  
Central District Office

ec: Paul L. Vandermeer

PLV/nsm Aleris Rolled Products

NPDES Compliance Inspection Report

SECTION A: NATIONAL DATA SYSTEM CODING				
Permit #	NPDES #	Inspection Type	Inspector	Facility Type
4IC00002	OH0003891	RI	S	2
Inspection Date	Entry Time	Exit Time	Notice of Violation	Significant Non-Compliance
8/7/2012	10:50 AM	11:45 AM	No	No

SECTION B: FACILITY DATA	
Name and Location of Facility Inspected	Permit Effective Date
Aleris Rolled Products, Inc. 1 Reynolds Road Ashville, OH 43103	7/1/2011
	Permit Expiration Date
	3/31/2015
Name(s) and Title(s) of On-Site Representatives	Phone Numbers
Eric Kellough, WWTP Operator	
Name and Title of Responsible Official	Phone Number
Harry Gulley , HSE Manager	(740) 601-6078

SECTION C: AREAS EVALUATED DURING INSPECTION		
Key: S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated		
S <sup>a</sup>	NPDES Compliance	Limit violation for <i>E. coli</i> satisfactorily addressed.
S	Operations & Maintenance	
S	Facility Site Review	
N	Collection System	
M*	Flow Measurement	Flow meter last calibrated on 6/15/11. Annual calibration required.
S	Receiving Waters	
S <sup>^</sup>	Laboratory	PACE Analytical Laboratory performs all analysis except pH and dissolved oxygen.

Comments: <sup>a</sup>Eric Kellough is currently OIT and will become a certified Class A operator by the end of 2012. The company shall forward a copy of the operator certificate to Paul Vandermeer via e-mail by December 31, 2012. \* The company shall calibrate the flow meter as soon as possible and shall notify Paul Vandermeer of the date which this is accomplished. <sup>^</sup>Calibration procedures for pH and D.O. sensors is satisfactory.

Signatures			
	8/8/12		8/8/12
Paul L. Vandermeer, Inspector Compliance & Enforcement Division of Surface Water Central District Office	Date	Mike Gallaway, Reviewer Section Manager Division of Surface Water Central District Office	Date

## Compliance Data for Aleris Rolled Products Inc between 10/1/2011 to 8/1/2012

### Summary

Permit Effluent Limit Violations: 1

Permit Effluent Code Violations: 0

Permit Effluent Frequency Violations: 0

Compliance Schedule Violations: 0

Limit Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
October 2011	001	E. coli	30D Conc	161	200.	10/1/2011