



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Huron County
Coble Village MHP WWTP
Ohio EPA Permit No. 2PY00030
NPDES Permit No. OH0125750

October 22, 2012

Mr. Wally Cook
128 Academy Drive
Wilmore, Kentucky 40390-1368

Dear Mr. Cook:

A review of the self-monitoring reports that are submitted under the National Permit Discharge Elimination System (NPDES) permit for the Coble Village Mobile Home Park (MHP) Wastewater Treatment Plant (WWTP) shows that this facility is in significant non-compliance (SNC) for the following parameters at Outfall Number 001: CBOD5, Nitrogen Ammonia and Chlorine. I am enclosing a list of violations for this facility for the period of January 1, 2012, through June 30, 2012.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters.

Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

Before we initiate enforcement action, we would like to work with you to achieve satisfactory progress to bring this facility back into compliance. Within **21** days of the date of this letter, please submit, in writing, the actions that you propose to undertake in order to return your facility into compliance with your NPDES permit. You will also need to give us a timetable for these actions that does not extend past **March 1, 2013**. These actions and timetable may also be submitted by email to me at andrew.gall@epa.state.oh.us.

If you wish to meet with us to discuss this matter, please contact me at 419-373-3003 within 10 days of receiving this letter in order to set up a meeting.

Sincerely,

Andrew Y. Gall
Division of Surface Water

/jlm

Enclosure

ec: Mr. Mike Lillo, Operator of Record
Thomas Poffenbarger, DSW-NWDO
Tracking

Detail - Limit Violations

Permit: 2PY00030

Period: 1/1/2012 6/30/2012

Permit No	Facility	Report Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PY00030*BD	Coble Village MHP	Jan 2012	001	00610	Nitrogen, Ammonia (30D Conc		3.0	3.95	1/1/2012
2PY00030*BD	Coble Village MHP	Jun 2012	001	00610	Nitrogen, Ammonia (30D Qty		0.05	.09889	6/1/2012
2PY00030*BD	Coble Village MHP	Jun 2012	001	00610	Nitrogen, Ammonia (30D Conc		1.0	2.21	6/1/2012
2PY00030*BD	Coble Village MHP	Jun 2012	001	00610	Nitrogen, Ammonia (1D Qty		0.08	.09889	6/13/2012
2PY00030*BD	Coble Village MHP	Jun 2012	001	00610	Nitrogen, Ammonia (1D Conc		1.5	2.21	6/13/2012
2PY00030*BD	Coble Village MHP	May 2012	001	50060	Chlorine, Total Resid 1D Conc		0.019	.05	5/9/2012
2PY00030*BD	Coble Village MHP	May 2012	001	50060	Chlorine, Total Resid 1D Conc		0.019	.06	5/12/2012
2PY00030*BD	Coble Village MHP	May 2012	001	50060	Chlorine, Total Resid 1D Conc		0.019	.08	5/23/2012
2PY00030*BD	Coble Village MHP	Jun 2012	001	50060	Chlorine, Total Resid 1D Conc		0.019	.2	6/13/2012
2PY00030*BD	Coble Village MHP	May 2012	001	80082	CBOD 5 day	30D Qty	0.57	1.67395	5/1/2012
2PY00030*BD	Coble Village MHP	May 2012	001	80082	CBOD 5 day	30D Conc	10	42.	5/1/2012
2PY00030*BD	Coble Village MHP	May 2012	001	80082	CBOD 5 day	1D Qty	0.85	1.67395	5/9/2012
2PY00030*BD	Coble Village MHP	May 2012	001	80082	CBOD 5 day	1D Conc	15	42.	5/9/2012