



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 16, 2012

Jim Lipnos
Homewood Corporation
2700 East Dublin-Granville Road, Suite 300A
Columbus, Ohio 43231

**Re: Storm Water Inspection at Hamilton Mass Fill Site / Franklin County
Permit #: 4GCD00080*AG**

Dear Mr. Lipnos:

This letter is written in follow-up to a construction storm water inspection that I conducted at the Hamilton Mass Fill Site located at (location) on July 30, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- The large stoke pile on the western end of the site has been adequately protected.
- I noted that the majority of the site has recently been established with vegetative cover. However, I remain concerned that this cover fails to meet the minimum vegetative density of 70 percent. Please ensure that additional seeding occurs this growing season to ensure effective erosion control concurrent with the winter months.
- Please submit to my attention the monitoring reports for your sediment pond discharge. Please be aware this is a specific requirement of the Darby General Storm Water Permit. A 45 milligram per liter target level is addressed in the General Permit.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (email preferred) to the action items addressed above within ten days from receipt of this letter.

Jim Lipnos
Homewood Corporation
Page -2-

A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

A handwritten signature in black ink, appearing to read 'Harry Kallipolitis', written in a cursive style.

Harry Kallipolitis
Storm Water Coordinator
Ohio EPA, Division of Surface Water
Central District Office

HK/hsm Hamilton Mass Fill Site Franklin county 8-1-2012