



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 22, 2012

RE: WAYNE COUNTY
WOOSTER WTP
NPDES NO: 3IN00129

Mayor Bob Breneman
City of Wooster
1020 Old Columbus Road
Wooster, Ohio 44691-4618

Dear Mayor Breneman

On October 4, 2012, this writer conducted an inspection of the three interceptor wells and air stripping units currently in use for the City of Wooster Water Treatment Plant. Kevin Givins, Utilities Manager, represented the City during the inspection. The intent of the inspection was to evaluate operations and maintenance of the treatment system.

The inspection of interceptor wells found the air stripping units in good operating condition. The outfalls and receiving stream were inspected and the effluent appeared to be of satisfactory condition.

A review of your discharge monitoring reports (DMRs) covering the period December 1, 2011 through October 1, 2012 revealed the following effluent violations:

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
3IN00129*CD	February 2012	001	39175	Vinyl Chloride	30D Conc	5	5.15	2/1/2012
3IN00129*CD	February 2012	001	38676	1,2-Dichloroethene	30D Conc	5	49.	2/1/2012
3IN00129*CD	February 2012	001	38676	1,2-Dichloroethene	30D Qty	.019	.12417	2/1/2012
3IN00129*CD	February 2012	001	38676	1,2-Dichloroethene	1D Conc	10	49.	2/6/2012
3IN00129*CD	February 2012	001	38676	1,2-Dichloroethene	1D Qty	.038	.12667	2/6/2012
3IN00129*CD	February 2012	001	38676	1,2-Dichloroethene	1D Conc	10	49.	2/27/2012
3IN00129*CD	February 2012	001	38676	1,2-Dichloroethene	1D Qty	.038	.12167	2/27/2012
3IN00129*CD	March 2012	001	38676	1,2-Dichloroethene	30D Conc	5	23.	3/1/2012
3IN00129*CD	March 2012	001	38676	1,2-Dichloroethene	30D Qty	.019	.05833	3/1/2012
3IN00129*CD	March 2012	001	38676	1,2-Dichloroethene	1D Conc	10	46.	3/2/2012
3IN00129*CD	March 2012	001	38676	1,2-Dichloroethene	1D Qty	.038	.11665	3/2/2012

CITY OF WOOSTER WATER PLANT
OCTOBER 19, 2012
PAGE 2 OF 2

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Respectfully,

A handwritten signature in black ink, appearing to read "Todd Surrena", written over a light blue circular stamp.

Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/cs

cc: Kevin Givins, Utilities Manager, City of Wooster

File: Industrial/Wooster WTP/Permit Compliance