



John D. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 29, 2012

Ron Younkin
Enchanted Acres MHP
555 Greenlawn Ave.
Columbus, OH 43223

Re: **Enchanted Acres MHP**
NPDES Permit 4PH00005/ OH0036722
Franklin County
Notice of Violation

Dear Mr. Younkin:

This is a **Notice of Violation** that the Enchanted Acres MHP is in Significant Non-Compliance (SNC) due to E. coli violations and failure to meet the Schedule of Compliance of the NPDES discharge permit. SNC is a programmatic definition used to identify those facilities that should receive priority enforcement attention either at the state or the federal level in association with federal reporting requirements at 40 CFR 123.45. The NPDES permit 4PH00005, effective September 1, 2010, included a Schedule of Compliance which required the facility to identify sources of inflow and infiltration (I&I) and ways to reduce the sources.

Additionally, I have not received a response regarding my previous inspection report dated May 31, 2012. Some of the action items within the report included:

- Investigation of UV disinfection or liquid sodium hypochlorite feed in attempts to reduce E. coli and chlorine residual violations.
- A maintenance schedule which would include repairs to the treatment system.
- Additional preliminary treatment.
- Addressing I&I and the compliance schedule.
- Determining if City of Columbus sewers are available and accessible and determining the feasibility of connecting to City of Columbus sewers.

I would like to meet on-site to discuss progress with the Schedule of Compliance. In addition to I&I work, I also want to discuss disinfection and the operations of the system. **The meeting should be held by November 16, 2012.** Please let me know your schedule availability.

Ron Younkin
Enchanted Acres MHP
Page -2-

Failure to achieve compliance with the NPDES permit will lead to enforcement action which may include civil penalties. If you have any questions or comments concerning this letter, please contact me at (614) 728-3846 or e-mail at cole.miller@epa.ohio.gov.

Sincerely,

A handwritten signature in cursive script, appearing to read "Cole Miller".

Cole Miller
Environmental Specialist
Compliance and Enforcement Unit
Division of Surface Water
Central District Office

ec: Cole Miller

CM/nsm 10-19-2012 Enchanted Acres NOV