



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 9, 2012

Jeff Holbrook
ODOT District 6
400 East William Street
Delaware, Ohio 43015

**RE: Storm Water Inspection Concerning Construction Activities Associated with ODOT
71 Reconstruction Project in Franklin County—Permit #: 4GC03346*AG**

Dear Mr. Holbrook:

This letter is written regarding the storm water inspection I conducted at the ODOT 71 Reconstruction Project in Franklin County on September 24, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:


Sediment Erosion Controls

- Please be aware measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected. This would include but not limited to a crimped straw mulch cover. Please submit to my attention the temporary seeding/protection schedule to ensure the erosion protection requirements are not violated.
- All storm water controls, including sediment erosion controls, will be inspected prior to the onset of the winter months to ensure compliance with the General Permit. Please be able to address, in your response letter, available dates through the month of November to conduct this joint inspection.

Jeff Holbrook
ODOT District 6
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Ohio EPA, Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO