



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

November 5, 2012

RE: SUM- SEIBERLING PHS 2
3GC05686*AG
STORMWATER/SWPPP
SUMMIT COUNTY

Mike Wytryszczewski
City of Akron Bureau of Engineering
166 S. High Street
Akron, Ohio 44308

Dear Mr. Wytryszczewski:

This office has reviewed the Storm Water Pollution Prevention Plan (SWPPP) for the above referenced subject and has the following comments:

- 1) The areas east and west of Springfield Lake Outlet and Haley's Ditch should be specifically addressed by the SWPPP as they are isolated from the erosion and sediment controls established for the rest of the site. To date these areas of heavy construction have impacted the streams as both have had diversion pipes installed. The SWPPP submitted does not provide adequate discussion or plans concerning the isolation and diversion of these streams and erosion control measures utilized during the construction of the bridge/roadway crossing.
- 2) The SWPPP must include Post Construction Best Management Plans (BMP's) for the bridge/roadway crossing as well as all roadways east and west of Haley's Ditch/Springfield Lake Outlet.

You are requested to submit the above listed information for our review no later than November 9, 2012. If you should have any questions concerning any of the above, feel free to contact this writer at (330) 963-1136 or by e-mail at phil.rhodes@epa.state.oh.us.

Sincerely,

Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR/cs

EC: Ray Kinney
Fred Fassnacht
Mike Wytryszczewski
Allison Giancola, Ohio EPA, DMWM, NEDO
Dave Dysle, Ohio EPA, DMWM, NEDO