



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

November 8, 2012

Mr. Brian Wilcox
 Village of Ansonia
 629 N. Main Street
 Ansonia, OH 45303

RE: Darke County, Ansonia WWTP, NPDES Permit Violations

Dear Mr. Wilcox:

Ohio EPA has completed a review of the Discharge Monitoring Reports covering the months of June thru September 2012 for the above referenced facility. The evaluation indicates violations of the conditions of your NPDES permit (NPDES Permit #OH0023884; Ohio EPA # 1PB00005*KD). The specific instances of non-compliance for the above mentioned review period are as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
June 2012	Phosphorus, Total (P)	Weekly	mg/l	1.5	1.6
June 2012	TSS	Monthly	mg/l	65	84
June 2012	Phosphorus, Total (P)	Monthly	mg/l	1.0	1.6
June 2012	pH	Daily	SU	9.0	9.1
June 2012	pH	Daily	SU	9.0	9.1
June 2012	pH	Daily	SU	9.0	9.2
June 2012	pH	Daily	SU	9.0	9.2
June 2012	pH	Daily	SU	9.0	9.3
June 2012	pH	Daily	SU	9.0	9.2
September 2012	Phosphorus, Total (P)	Weekly	mg/l	1.5	2.4
September 2012	TSS	Monthly	mg/l	65	79
September 2012	Phosphorus, Total (P)	Monthly	mg/l	1.0	2.4
September 2012	Phosphorus, Total (P)	Monthly	kg	1.52	1.63
September 2012	Fecal Coliform	Weekly	#/100ml	2000	3464
September 2012	Phosphorus, Total (P)	Weekly	mg/l	1.5	2.5


Mr. Brian Wilcox
Village of Ansonia
November 8, 2012
Page 2

Please inform this office, in writing, by November 28, 2012, as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations.

Please be advised that failure to comply with the effluent limits, monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code 6111.

If you have any questions or concerns regarding this matter, please feel free to contact at (937) 285.6033 or via email at glen.vonderembse@epa.ohio.gov.

Sincerely,



Glen Vonderembse
Environmental Engineer
Division of Surface Water

GV/ff