



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

November 14, 2012

Numan Babieh  
ODOT District 5  
9600 Jacksontown Road  
SE Jacksontown, OH 43030

**Re: Storm Water Inspection at LIC- 158-0.58 (PID 84700) PID- 84700  
Licking County Permit Number: 4GC03667\*AG**

Dear Mr. Babieh,

This letter is written in follow up to a construction storm water inspection I conducted at LIC- 158-0.58 (PID 84700) PID- 84700 located at Interstate 70 and State Route 158 interchange in Village of Kirkersville, OH on November 9, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

**Sediment and Erosion Controls:**

- Sediment basin continue to be well maintained and functioning as intended
- Sediment controls such as perimeter silt fence and constructed inlet protections appear well maintained and function as intended with the exception of minor maintenance to the silt fence on the northern end of the project.
- Please ensure all bleeders are routed in such a manner in which they will be intercepted with an appropriate sediment control for treatment.


**21 Day Rule:**

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. I noted the northern ramps have been seed with vegetation becoming established.

Numan Babieh  
ODOT District 5  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

A handwritten signature in black ink, appearing to read 'Harry Kallipolitis', written in a cursive style.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office