



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 17, 2012

Daniel Weaver
Ferguson Construction Co
400 Canal Street
PO Box 726
Sidney, OH 45365

**Re: Notice of Violation Storm Water Inspection at Florida Production
Engineering, Pickaway County, Permit Number: 4GC03816*AG**

Dear Mr. Weaver:

This letter is written in follow up to a construction storm water inspection by Elizabeth Pleta and Alicia Rector of the Ohio EPA, at Florida Production Engineering located at 30627 Orr Road on July 6, 2012. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- This site appears to be void of any sediment controls. The General Permit states that all sediment controls must be implemented prior to initial grading of the site. Please implement these controls immediately to ensure compliance with the General Storm Water Permit.
- A contained concrete wash out area must be established in order to meet the minimum requirements of the general permit (See Figure 1).
- Inlets require sediment controls and protection (See Figure 2).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Daniel Weaver
Ferguson Construction Co.
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

A handwritten signature in black ink, appearing to read "Harry Kallipolitis".

FOR
Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office