



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

November 13, 2012

Jeff Krebs
Lincoln Construction
4790 Shuster Road
Columbus, Ohio 43214

**Re: Construction Storm Water Inspection at The Crossing Community Church
Permit Number: 4GC03936 *AG**

Dear Mr. Krebs:

This letter is written regarding a storm water inspection I conducted at The Crossing Community Church located on Britton Parkway in Franklin County on November 8, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The perimeter silt fence is installed and properly functioning on this date. Please ensure continued maintenance via your mandated self inspection reports every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches.
- The two sediment impoundments must be the next step in the construction process. Please ensure positive drainage to the impoundments via earthen berms or ditches, if necessary, prior to the storm sewer installation.
- Please ensure a stabilized construction entrance is maintained to minimize vehicle tracking onto public roads
- All barren areas which remain idle in excess of 21 days must be protected from erosion in preparation for the upcoming winter months. Given the time of year a crimped mulch cover or equivalent is expected

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office