



John R. Kasich, Governor  
Richard Cordell, Lt. Governor  
Michael R. Nally, Director

November 13, 2012

Don Sherman  
Fairfield County Utilities Department  
210 East Main Street  
Room 302  
Lancaster, OH 43130

**Re: Fairfield County Utilities – 6670 Lockville Road, Fairfield County  
Permit Number: 4GC03409 \*AG**

Dear Mr. Sherman:

This letter is written regarding a storm water inspection that I conducted on November 5, 2012, at Fairfield County Utilities located at 6670 Lockville Road Northwest, in Carroll, Ohio. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

It appears that construction is nearly complete for this project. It appears that there was an attempt at final stabilization of the site with seed and straw. Please be aware that the definition of final stabilization is to have a density of 70% coverage without any large barren areas. It does not appear that the site currently meets the definition of final stabilization at this time. Given the time of year, alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months. Please see attached pictures.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosure

ec: Greg Sanders, DSW/CDO

