



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

November 20, 2012

RE: TRUMBULL COUNTY
HUBBARD TOWNSHIP
TRUCK WORLD TRUCK STOP
NPDES PERMIT NO. OH0084000
OHIO EPA PERMIT NO. 3IG00040

Mr. Barry Brocker, CFO
Truck World, Inc.
P.O. Box 248
Hubbard, Ohio 44425

Mr. Brocker:

Ohio EPA performed a compliance evaluation inspection of the treatment works serving the above-referenced facility on November 15, 2012. Mr. Tim Schubert represented Truck World Truck Stop and Mr. Jon Jamison and the undersigned represented Ohio EPA. The purpose of the inspection was to evaluate the operation and maintenance of the treatment works, and determine the facility's compliance with the terms and conditions of its National Pollutant Discharge Elimination System (NPDES) permit.

The existing treatment system consists of an oil/water separator. Effluent from the oil/water separator is discharged to a storm sewer that is tributary to Little Yankee Run. At the time of the inspection, the general operation and maintenance of the system appeared to be satisfactory. Effluent from the treatment works appeared to be clear.

A review of the facility's electronic Discharge Monitoring Reports received by Ohio EPA for the period October 2009 - October 2012 indicated violations of the terms and conditions of the NPDES permit. The specific instances of noncompliance include:

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
3IG00040*DD	March 2010	001	00552	Oil and Grease, Hexane	1D Conc	10	87.9	3/26/2010
3IG00040*DD	August 2010	001	00400	pH	1D Conc	9.0	10.18	8/31/2010
3IG00040*ED	February 2011	001	00400	pH	1D Conc	9.0	9.28	2/18/2011
3IG00040*ED	January 2012	001	00552	Oil and Grease, Hexane	1D Conc	10	10.5	1/16/2012

Please provide to this office, within 14 days' receipt of this letter, written documentation describing the actions that will be taken, or have been taken, to address the above-referenced violations and/or deficiencies. Your response shall include specific dates for the initiation and completion of this action plan. Please be advised that violations of the NPDES permit are subject to appropriate enforcement actions pursuant to Chapter 6111 of the Ohio Revised Code.

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1120.

Respectfully,

Tomás Parry, P.E.
Environmental Engineer
Division of Surface Water

TP/cs